

Water Distribution Systems

1/8

Components


① Pipelines

- min dia 6 in
- looped
- ductile iron or plastic

Linsley
Table 15.1
p. 498
elements of
water supply
systems

② Pumps

- axial
- centrifugal



③

Flow (Q)

Pressure minimum

- 25 psi in Delaware
- 35 psi in 10 state standards

④

Storage

- Tanks (finished, treated water)
- Reservoir (raw water)

⑤

Valves / meters

⑥

Treatment Plant

⑦


Supply: Surface water (streams, rivers, lakes)
Groundwater (wells)

2/8

Pipelines

Transmission Mains
Feeder
Distribution

(greater than 24")
18"-24"
6"-18"



Pressure

min. 25 psi
35 psi

OE Public Service Commission
Great Lakes, 10 state standards

Normal 60-65 psi

Max 90 psi

Velocity

max = 25 fps
Normal = 5-10 fps

3/8

Water Demand

Distribution of Water Demand in NCC
(Hurd, 1998)

<u>Category</u>	<u>Demand</u>	<u>% of total</u>
Residential	33	49%
Commercial	14	20
Industrial	12	18
Unaccounted for (loss)	<u>9</u>	<u>13</u>
	68 mgd	100%

Per Capita Water Demand

Normal 100 - 150 gpcd
#

Peak 150 - 300 gpcd

Peakiny Factor 1.5 - 2.0

Per dwelling


Normal 300 gpd/dw @ 3 people/dw

Peak 450 - 900 gpd/dw

(Tidewater, 1998)

9/15/01 C 1EG 490 4/8

Public Water Demand: Northern New Castle County June 2003-May 2004



Compiled by the University of Delaware, Institute for Public Administration, Water Resources Agency using data from: Artesian Water Co., City of Newark, New Castle Municipal Services Commission, United Water Delaware and City of Wilmington

— Monthly Average — Historic Peak (7/18/97) — June 2002 - May 2003 — June 2003-May 2004 — June 2004-May 2005

3/ 5/8

New Castle County Population

$$\begin{array}{l} 1990 \quad 450,000 \text{ pop.} \times \frac{\text{Normal}}{150 \text{ gpcd}} = 67.5 \text{ mgd} \times 1.5 = \frac{\text{Peak}}{101 \text{ mgd}} \\ 2000 \quad 500,000 \text{ pop} \times 150 \text{ gpcd} = 75 \text{ mgd} \times 1.5 = 112 \text{ mgd} \end{array}$$

No. NCC Supply / Demand Projections

Year	(mgd) Supply	(mgd) Demand	T/-	Volume* (mg)
2000	73.0	86.0	-13.0	-780
2010	73.0	88.0	-15.0	-900
2020	73.0	90.0	-17.0	-1,020

*Assumes 60 day drought period

see Fifth Report to Governor's General Assembly
www.wr.udel.edu publications

3/ 5/8

New Castle County Population

$$\begin{array}{l} 1990 \quad 450,000 \text{ pop.} \times \frac{\text{Normal}}{150 \text{ gpcd}} = 67.5 \text{ mgd} \times 1.5 = \frac{\text{Peak}}{101 \text{ mgd}} \\ 2000 \quad 500,000 \text{ pop} \times 150 \text{ gpcd} = 75 \text{ mgd} \times 1.5 = 112 \text{ mgd} \end{array}$$

No. NCC Supply / Demand Projections

Year	(mgd) Supply	(mgd) Demand	T/-	Volume* (Mg)
2000	73.0	86.0	-13.0	-780
2010	73.0	88.0	-15.0	-900
2020	73.0	90.0	-17.0	-1,020

*Assumes 60 day drought period

see Fifth Report to Governor's General Assembly
www.wr.udel.edu publications

6/8

Design of Water Tank Storage Volume for the City of Newark

Given: Population of Newark, DE = 28,000
 Normal Per Capita Water Use = 150 gpcd
 Fireflow Requirement = 5000 gpm over 5 hours

Water Tank Storage Volume Demand = Volume of Demand in Excess of Maximum Daily Demand
 + Fire Storage
 + Emergency Storage for 1 day at Average Daily Demand
 = Peaking Factor*(Population)*(Normal Per Capita Water Use)*(Factor of Safety)
 + Fire Flow Rate*(Duration of Fire)
 + Population *(Normal Per Capita Water Use)
 = 2.0*(28,000)*(150 gpcd)*(0.25)
 + 5000 gpm*(60 min/hr)*(24 hr/day)*(5hr)*(1 day/24 hr)
 + 28,000*(150 gpcd)
 = 2.1 MG
 + 1.5 MG
 + 4.2 MG
 = 7.8 MG


Therefore, total volume of storage tanks in the City of Newark should be 7.8 million gallons. We'll review this in class on Wednesday.

Pumping Stations

• Centrifugal



• Axial



Horsepower:

$$hp = \frac{Q \gamma H}{550}$$

where: Q = Discharge (cfs)
 γ = spec. wt.

H = Total Dynamic Head

$$550 = \frac{ft \cdot lb}{sec \text{ conversion}}$$

(efficiency) x Actual HP = Theoretical HP

Pumping Head


$$TDH = h_L + h_f + h_v$$

TDH = Total Dynamic head (ft)

h_L = Total static head

h_f = Friction head losses "C"

h_v = Velocity head $\left(\frac{v^2}{2g}\right)$




Download EPANET 2 Water Distribution Model

<http://www.epa.gov/ORD/NRMRL/wswrd/epanet.html>

- ① Download executable program
- ② Download user manual (bookmark)
- ③ Print out ch. 2, tutorial, only.

...mps is between 50 and ... reported. Pump efficiency pump.²³

... characteristics and is required ... This is done by plotting ... characteristic curves. The ... head curve and the pump-head ... the pump will be operating. ... is also as close as possible 5-28.



(b) Pump operations of equal pumps.

el. For series operation at a heads added by each pump. ... by the number of pumps ... when two pumps are used in ... a given system head curve is

●EXAMPLE 5-6

A pumping station is to be designed for an ultimate capacity of 1200 gpm at a total head of 80 ft. The present requirements are that the station deliver 750 gpm at a total head of 60 ft. One pump will be required as a standby.

○Solution

- (a) The total curve for dynamic head versus discharge is plotted as shown in Fig. 5-29. Values for the curve are obtained as indicated in Sec. 5-11.
- (b) Consider that three pumps will ultimately be needed (one as a standby). Determine the design flows as follows:




FIGURE 5-29. Solution for Example 5-6.

- 1 Two pumps at 1200 gpm at 80 ft of TDH
 - 2 One pump at 1200/2 = 600 gpm at 80 ft of TDH
 - 3 One pump must also be able to meet the present requirements of 750 gpm at 60 ft of TDH.
- (c) From manufacturers' catalogs, two pumps, *A* and *B*, are found that will meet the specifications. The characteristic curves for each pump are shown in Fig. 5-29. The intersection of the characteristic curves with the system-head curve indicates that pump *A* can deliver 750 gpm at a TDH of 60 ft while pump *B* can deliver 790 gpm at a TDH of 62 ft. A check of the efficiency curves for each pump indicates that pump *B* will deliver the present flow at a much greater efficiency than pump *A*. Therefore, select pump *B*.